

TOSHIBA G8000 Series UPS

Installation Planning Guide for 100kVA UPS

Standard System: 480V Input, 480Y/277V Output

| General Mechanical Information | | |
|---------------------------------------|--------|------------------------------------|
| Dimensions (W x D x H) | Weight | Approximate Full-Load Heat Loss |
| Inches | Lbs. | Btu/Hr |
| 55.1 x 31.5 x 78.75 | 2,756 | 30,840 |

| Primary AC Input (480V 3-Phase / 3-Wire) | | | | | |
|---|-------|------|---|--|---|
| Maximum Input Power Demand | | | Suggested External Overcurrent Protection | Suggested Minimum Feeder Wire Size Per Phase | Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit |
| kVA | PF | Amps | Amps | AWG or kcmil at 75° C Temp. Rating | Feet |
| 100 | >0.98 | 120 | 150 AT | (1) x 1/0 | 480 |

| Alternate (Bypass) AC Input (480V 3-Phase / 4-Wire) | | | | | |
|--|-----|------|---|--|---|
| Maximum Input Power Demand | | | Suggested External Overcurrent Protection | Suggested Minimum Feeder Wire Size Per Phase / Neutral | Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit |
| kVA | PF | Amps | Amps | AWG or kcmil at 75° C Temp. Rating | Feet |
| 100 | 0.8 | 120 | 150 AT | (1) x 1/0 / (1) x 4/0 | 380 |

| Battery Input (360VDC Nominal) | | | | |
|--|---------------------------------------|---|--|---|
| Battery Capacity Required for Full Load Output | Maximum Discharge at Full Load Output | Suggested External Overcurrent Protection | Suggested Minimum Feeder Wire Size Per Phase | Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit |
| kWB | Amps DC | Amps | AWG or kcmil at 75° C Temp. Rating | Feet |
| 86.9 | 301 | 400 AT | (2) x 3/0 | 70 |

| AC Output (480/277V 3-Phase / 4-Wire) | | | | | |
|--|-----|------|---|--|---|
| Rated Output Power | | | Suggested External Overcurrent Protection | Suggested Minimum Feeder Wire Size Per Phase / Neutral | Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit |
| kVA | PF | Amps | Amps | AWG or kcmil at 75° C Temp. Rating | Feet |
| 100 | 0.8 | 120 | 150 AT | (1) x 1/0 / (1) x 4/0 | 380 |

Important Notes:

1. Maximum Current required at Primary AC Input based on full load output and maximum battery charging current.
2. Output load conductors are to be installed in separate conduit from input conductors.
3. Control wires and power wires are to be installed in separate conduits.
4. Recommended AC input and output overcurrent protection based on continuous full load current per NEC.
5. Wiring shall comply with all applicable national and local electrical codes.
6. Grounding conductors to be sized per NEC Article 250-122. Neutral conductors to be sized per NEC Article 310.15.
 - Primary AC Input: 3 ϕ , 4-wire + ground.
 - Alternate AC Input: 3 ϕ , 4-wire + ground.
 - AC Output: 3 ϕ , 4-wire + ground.
 - DC Input: 2-wire (Positive/Negative) + ground.
7. Nominal battery voltage based on the use of VRLA type batteries (2.0 volts/cell nominal).
8. Maximum battery discharge current based on lowest permissible discharge voltage of 1.6 VPC.
9. DC wires should be sized to allow not more than a 2-volt drop at maximum discharge current.
10. Weights do not include batteries or other auxiliary equipment external to the UPS.
11. Sizing calculations based on the following assumptions:
 - Not more than 3 current-carrying conductors installed in steel conduit in ambient temperature of 30 degrees C.
 - Temperature rating of conductors and terminals: 90 deg. C.
 - Feeder distance calculations based on NEC Tables 8 and 9 data, allowing for 2% AC voltage drop.
 - Reference: 2002 NEC Handbook. Consult latest edition of applicable national and local codes for possible variations.
12. Ratings of wires and overcurrent devices are suggested minimums. Consult with a registered Professional Engineer within your local area for proper size selections.

TOSHIBA INTERNATIONAL CORPORATION
 13131 West Little York Road
 Houston, TX 77041
 Telephone: (800) 231-1412
 Fax: (713) 896-5212
 Corporate Web Site: www.tic.toshiba.com
 Group Web Site: www.toshibaups.com

Free Manuals Download Website

<http://myh66.com>

<http://usermanuals.us>

<http://www.somanuals.com>

<http://www.4manuals.cc>

<http://www.manual-lib.com>

<http://www.404manual.com>

<http://www.luxmanual.com>

<http://aubethermostatmanual.com>

Golf course search by state

<http://golfingnear.com>

Email search by domain

<http://emailbydomain.com>

Auto manuals search

<http://auto.somanuals.com>

TV manuals search

<http://tv.somanuals.com>