# BRSAN®

### **SPECIFICATION SHEET**

## MODEL QTX100HL COMBINATION UNIT HEATER / FAN / LIGHT / NIGHT LIGHT

#### FEATURES

#### GRILLE:

- White polymeric grille
- Snap-in light diffusing lens for (2) 60W bulbs and 7W night light (not included)

#### VENTILATOR:

- Resilient anti-vibration mounts
- Plug-in, permanently lubricated motor
- Low sound, high performance blower wheel
- Polymeric, 6" round damper/duct connector for optimal performance - with 1-1/8" long tapered sleeve and no metallic clatter

#### HEATER:

- 1500 watts, with metal blower wheel for efficient, even heating
- Plug-in, permanently lubricated motor functions independent of ventilator

#### HOUSING:

- Rugged galvanized steel housing
- Adjustable mounting brackets span up to 24"
- Suitable for use in insulated ceilings (Type I.C.).

NOTE: For installation in ceilings up to a 12/12 pitch

CONTROL (Included):

- Three, independent switches control four functions
- White finish face plate
- Fits standard single-gang opening

#### **SPECIFICATIONS**

VOLTS	AMPS	SONES	CFM	DUCT
120	14.6	1.2	100	6" Round

#### **TYPICAL SPECIFICATION**

Combination unit shall be Broan Model QTX100HL.

Unit shall have galvanized steel housing and adjustable mounting brackets.

Unit must be rated to handle a (2) 60W bulbs.

Fan, heater, light, and night light shall be separately controllable. Motor shall be permanently lubricated.

Heater to deliver 1500 Watts of fan-forced heat.

Air delivery shall be no less than 100 cfm and sound levels no greater than 1.2 sones . All air and sound ratings shall be certified by HVI.


Unit shall be UL listed.

Combination unit to be suitable for use in insulated ceilings. (Type I. C.)



HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in a state-of-the-art test laboratory. Sones are a measure of humanly-perceived loudness, based on laboratory measurements.





Broan-NuTone LLC Hartford, Wisconsin www.broan.com 800-558-1711

		i	
REFERENCE	QTY.	REMARKS	Project
			Location
			Architect
			Engineer
			Contractor
			Submitted by Date

Free Manuals Download Website <u>http://myh66.com</u> <u>http://usermanuals.us</u> <u>http://www.somanuals.com</u> <u>http://www.4manuals.cc</u> <u>http://www.4manuals.cc</u> <u>http://www.4manuals.cc</u> <u>http://www.4manuals.com</u> <u>http://www.404manual.com</u> <u>http://www.luxmanual.com</u> <u>http://aubethermostatmanual.com</u> Golf course search by state

http://golfingnear.com Email search by domain

http://emailbydomain.com Auto manuals search

http://auto.somanuals.com TV manuals search

http://tv.somanuals.com