1¹/₂ Hour Fire Dampers and

Dampers-Horizontal Mount

(see complete marking on product)"

(see complete marking on product)"

Standards UL 555 & 555S

1¹/₂ Hour Combination Fire Smoke

"UL CLASSIFIED to Canadian safety standards

Classifications Filed at UL under Listing #R13317

INSTALLATION INSTRUCTION SUPPLEMENT FD & DFD Series

FSD Series

"UL CLASSIFIED

Refer to: 'Installation Instructions for FD, DFD, SSFD, & KFD Models' (Part #452763)

or 'Installation Instructions for FSD-XXX, DFD-XXX, SSFSD-XXX & <u>CFSD-XXX Series Fire & Combination Fire Smoke Dampers</u>' (Part #461336)

or

'Installation Instructions for FD & DFD 150X Series Curtain Fire Dampers' (Part #453946) for additional details.

These instructions apply to 1½ hour rated combination fire smoke dampers and curtain fire dampers mounted horizontally in concrete floors. Specific requirements in these instruction are mandatory. These instructions meet the requirements of UL 555. Installation shall comply with the requirements of NFPA 90A (Standard for the Installation of Air Conditioning and Ventilating Systems) and UL Classification R13317.

Ventilating Systems) and UL Classification R13317. maximum size of 144 in. W x 96 in. H (3658mm x 2438mm) may be installed as illustrated




Dampers up to a maximum size of 144 in. W x 96 in. H (3658mm x 2438mm) may be installed as illustrated below.

Fire damper and sleeve assemblies 144 in. W x 96 in. H (3658mm x 2438mm) and smaller only require retaining angles on top of the concrete floor. Retaining angles must be installed on top of the floor and attached to the sleeve and the floor.

Retaining angles must be attached to the sleeve.

- Retaining angles must be a minimum of 16 gauge (1.5mm) steel and have a minimum of $1\frac{1}{2}$ in. x $1\frac{1}{2}$ in. (38mm x 38mm) legs.
- Retaining angles must be attached to the sleeve using one of the methods shown below:
 - tack or spot welds
 - #10 sheet metal screws or 1/4 in. nuts and bolts
- •Retaining angles must be attached to the concrete floor using the method shown below:
- Steel anchors or self tapping concrete screws penetrating concrete floor a minimum of 1¼ in. (32mm)
- A minimum of two connections per side with a maximum spacing of 6 in. (152mm) on center
- Retaining angles must overlap the floor a minimum of 1 in. (25mm)





Copyright © 2008 Greenheck Fan Corporation 468236 Single Side Retaining Angle-Horizontal Mount Rev.3 August 2008

P.O. Box 410 • Schofield, WI 54476-0410 • 715.359.6171 • greenheck.com

Free Manuals Download Website <u>http://myh66.com</u> <u>http://usermanuals.us</u> <u>http://www.somanuals.com</u> <u>http://www.4manuals.cc</u> <u>http://www.4manuals.cc</u> <u>http://www.4manuals.cc</u> <u>http://www.4manuals.com</u> <u>http://www.404manual.com</u> <u>http://www.luxmanual.com</u> <u>http://aubethermostatmanual.com</u> Golf course search by state

http://golfingnear.com Email search by domain

http://emailbydomain.com Auto manuals search

http://auto.somanuals.com TV manuals search

http://tv.somanuals.com